

## CITY OF PATASKALA

## RESOLUTION 2015-062

Passed October 5, 2015

A RESOLUTION AUTHORIZING THE CITY ADMINISTRATOR TO ENTER INTO A CONTRACT WITH INDUSTRIAL FLUID MANAGEMENT FOR THE WATER TREATMENT PLANT NUMBER 2 WATER RECLAMATION FACILITY SAND BED MEDIA REPLACMENT PROJECT.

**WHEREAS**, the Pataskala Utility Department provides drinking water to customers through the Water Treatment Plant; and

WHEREAS, the recent Ohio Environmental Protection Agency governs regulations to meet treatment expectations to ensure the best product to the customers; and

WHEREAS, the Water Treatment Plant 2 has a Water Reclamation Facility for treated water discharge to the South Fork Licking River; and

WHEREAS, the sand bed media captures iron deposits prior to release to the receiving stream; and

WHEREAS, the media has achieved its iron saturation limit and needs to be replaced to ensure proper treatment; and

WHEREAS, the department desires to contract with Industrial Fluid Management for the media replacement (Quote #12713) project in an amount not to exceed dollars twenty two thousand dollars (\$22,000); and

WHEREAS, funding for the purchase of this project includes 2015 Capital Improvement Funds through the Water Treatment Plant Improvement Fund. This project has resulted in a supplemental (3<sup>rd</sup> reading 10-5-15) to ensure sufficient capital funds for this project under the 2015 Utility Budget.

NOW THEREFORE BE IT RESOLVED BY THE COUNCIL OF THE CITY OF PATASKALA, COUNTY OF LICKING, STATE OF OHIO, A MAJORITY OF MEMBERS CONCURRING THAT:

Section 1: The City Administrator is hereby authorized and directed to enter into a contract with Industrial Fluid Management for the media replacement (Quote #12713) project in an

amount not to exceed dollars twenty two thousand dollars (\$22,000)

Section 2: This Resolution shall become effective from and after the earliest period allowed by law.

ATTEST:

Kathy M. Hoskinson, Clerk of Council

Michael W. Compton, Mayor

**APPROVED AS TO FORM:** 

Rufus B. Hurst, Law Director