



**City of Pataskala Utility Department
Nathan W. Coey, Utility Director**

➤ **Director Update**

- June preventative maintenance and service work on all generators is complete. No issues were reported in the testing, inspection, and maintenance work.

➤ **Water Department**

- Well#2 at WTP2 suffered failure. The pump and motor required full replacement. The wrong pump size was received by the contractor noticed by the significantly low gallons per minute. The proper pump is secured and should be in service by the end of June.
- A new pressure transducer controller has been installed and programmed at Beechwood Trails Tower 1.

➤ **Water Reclamation Department**

- The bypass pipe work for the Creek Road lift station has been tested and cleaned. Modifications have been made to properly utilize this in the event of significant failure of the Creek Road Station to prevent overflows. Modification will also allow for draining north lagoon if desired.
- WRF staff gave tours to the members of the West Licking Fire Department to provide familiarity of the facility in the event of emergency. We have scheduled rescue training at the WRF with the Fire Department. We will focus on tank and manhole rescue plans.
- Plans are in place to run water and electric to the new biosolids building utilizing our staff.

➤ **Billing Department Update**

- Utility portion of the audit is complete. The end of the audit includes organizing records for storage per retention plan.

Highest Regards, Nathan W. Coey, Utility Director