



City of Pataskala *Legislative Report to Council*

Legislative Report

May 18, 2020 Council Meeting

Unfinished Business

A. Ordinances

➤ **ORDINANCE 2020-4364 - MAYOR'S COURT BAILIFF- 3rd READING**

With the recent passing of Bob Wheeler, the city's Mayor's Court has been without a regular bailiff. The Administration formally created a position description for the bailiff position (none had existed prior), and had the document approved by the Personnel Board of Review (PBR) on March 25th. The Administration is now requesting that Council approve the position so that it can be advertised, and someone hired to fill the position prior to the court reopening its operations.

➤ **ORDINANCE 2020-4365 – 3rd READING**

This ordinance would approve the creation of the Economic Development Director position. The Development Committee provided comments on the position description on April 8, 2020. The position description was approved by the Personnel Board of Review on April 14, 2020.

New Business

A. Ordinances

➤ **ORDINANCE 2020-4366 – 1st READING**

An ordinance to proceed with constructing proposed sidewalk improvements upon adjacent lots located on the east side of Oak Meadow Drive and declaring an emergency

B. Resolutions

➤ **RESOLUTION 2020-042 – A RESOLUTION AUTHORIZING AND DIRECTING THE CITY ADMINISTRATOR TO EXECUTE A CONTRACT WITH HENRY P. THOMPSON COMPANY FOR ULTRAVIOLET SYSTEM REPAIRS AT THE WATER RECLAMATION FACILITY**

The City of Pataskala Utility Department uses an ultraviolet (UV) system to disinfect the effluent from the Water Reclamation Facility (WRF) before it enters the South Fork of the Licking River. This system consists of UV bulbs, ballasts, sensors, wires and a control unit. We have a two bank system, one for primary and one for backup.

The control unit for one of the banks allowed water to get into it, causing the computer control components to fail. Henry P. Thompson has provided us a quote not to exceed \$16,169.50 to replace the components with an upgraded system better suited to be used in an outdoor setting. This quote will cover all of the components, their programming and installation.

It should be noted that both of the banks will need to be operational before we begin the WRF upgrade project in June to ensure that we are able to provide the best treatment processes possible while we bypass the normal treatment process during the upgrade construction.

I recommend approval of Resolution 2020-042.